

Date	Time	Contractor	Question	Answer	Response Posted
2/10/2026	1:00	GM Construction	Are joint seals hot pour or silicone?	The joint sealing compound shall be silicone, as specified in the NCTCOG "Standard Specifications for Public Works Construction." All NCTCOG specifications and construction standards shall be followed.	2/10/2026