

Question No.	Date	Contractor	Firm	Question	Response
1	8/7/2026	Larry Kennon	Ashlar	Does any of the exposed concrete require paint or opaque sealer?	Paint or opaque sealer is not required
2	8/7/2026	Larry Kennon	Ashlar	Does the C402 Steel Rail require paint or powder coating over the galvanized finish?	No paint or coating is required over the galvanized finish
3	8/7/2026	Larry Kennon	Ashlar	The Bid Form does not include bridge quantities. Can they be added or can we use our own spreadsheet.	This is a lump sum contract. Quantities will not be provided.
4	8/7/2026	Larry Kennon	Ashlar	I do not see enough information to get quotes on the pedestrian rail shown on Sheet B-24 and there appears to be two types shown. Is there additional information elsewhere in the bid documents?	I believe aesthetics team is responsible for the custom rail. Those details can be shown on the aesthetics sheets.
5	8/7/2026	Larry Kennon	Ashlar	I am not sure what the dewatering bid item is for. Can you explain the requirements for this item. Also , is it an allowance?	Dewatering is included in the event that the bridge contractor believes that he will need it.
6	8/7/2026	Larry Kennon	Ashlar	Is there a maximum amount for the mobilization bid item? TxDOT allows up to 10%.	A mobilization of 10% maximum is allowed. An addendum will be issued modifying the mobilization line item to indicate 10% maximum for each section.
7	8/12/2026	n/a	n/a	Are epoxy coated bars or non-coated bars be required in the deck?	Only epoxy coated bars are accepted in that portion of the deck.
8	8/14/2026	Mason Oliver	Urban Infraconstruction	Plan sheets B-11 and B-21 show that the T402 Rail is over a bay that shows deck panels. The slab details do not have a detail for the U-bars for this condition. Can the engineer provide a detail for this condition ?	We will issue an addendum with a detail.
9	8/14/2026	Mason Oliver	Urban Infraconstruction	The proposal requires bidders to include the number of days for substantial completion and final completion. How will the number of days be evaluated against the price to determine the Successful Bidder?	Bids will be evaluated based on the best value as a combination of price and durations.
10	8/18/2026	William Mee	McMahon Contracting	How will drill shafts be paid if they run long versus depth shown on plans?	Please refer to Article 4 of the contract documents.